

## Linda Pinkul

---

**From:** Linda Pinkul [lindapinkul@wispertel.net]  
**Sent:** Thursday, February 18, 2010 10:13 AM  
**To:** lindapinkul@wispertel.net  
**Subject:** RE: Septic Info 5008 Cameyo Drive Indian Hills, CO

---

**From:** Craig Sanders [mailto:csanders@co.jefferson.co.us]  
**Sent:** Thursday, February 18, 2010 8:56 AM  
**To:** 'Linda Pinkul'  
**Subject:** RE: Septic Info 5008 Cameyo Drive Indian Hills, CO

Here's the main page, as-built, and engineering drawings.



**Craig Sanders, R.S.**  
Environmental Health Services Division  
Jefferson County Public Health  
1801 19th Street, Golden CO 80401  
Office: 303 271-5759 Fax: 303 271-5760



Please note: E-mail and other communications received by JCPH may be subject to the Colorado Open Records Act as a public record.



**Please consider the environment before printing this email**

536  
F.S.

JEFFERSON COUNTY HEALTH DEPARTMENT  
250 So. Kipling St., Lakewood, Colorado 80226  
Phone 338-6301

NO. 8162

PERMIT FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM RENEWAL

Permit issued to: Jim Kocol

Address: 27192 Hilltop Drive Evergreen, Colorado 80439

Location of System:

Legal Description: SE $\frac{1}{4}$ , SE $\frac{1}{4}$ , Section 8, T4S, R70W, 6PM

Street Address: \_\_\_\_\_

Conditions for Permit Issuance: 1. A preliminary inspection must be made by this department upon completion of the 6 foot excavation. 2. The designing engineer shall certify in writing to this department that the construction and installation of this system has been completed with the terms of this permit. 3. Maintain a minimum distance of 200 feet between sand filter and all walls (existing or proposed). 4. Maintain a minimum distance of 25 feet between absorption bed and all dry gulches.

Refer to this permit number regarding any inquiry or request. No acceptance of this system will be made without final inspection by this Department.

Contact this Department to arrange for required inspection(s).

Tank Capacity: 1000 Gal. (minimum)

Absorption area: 710 Sq.ft. (minimum)

Application Approval Date: January 11, 1980

THIS PERMIT EXPIRES ONE-YEAR FROM THIS DATE.

Paul A. Johnson, M.D.  
Health Officer

This individual sewage disposal system was installed by \_\_\_\_\_  
(License No.) W/A and has been inspected and accepted for use by a representative of the Jefferson County Health Department. The owner assumes all responsibility in case of failure or inadequacy of this sewage disposal system. Completed plot plan on reverse side.

Date: July 15, 1980. Sanitarian: Richard B. Bell

( ) Engineer's letter received

The as-built does not show the house, which was constructed later..



